


VERIFICATION OF CONFORMITY


S

| | | |
|---------------------------------------|---|--|
| Applicant Name & Address | : | Samil Power Co., Ltd. No.6, Xuefengshan Road, Suqian High-tech Industrial Development Zone, Jiangsu Province, P.R. China |
| Manufacture Name & Address | : | Samil Power Co., Ltd. No.6, Xuefengshan Road, Suqian High-tech Industrial Development Zone, Jiangsu Province, P.R. China |
| Product(s) | : | PV Grid-tied Inverter |
| Model(s) | : | SolarLake 12000TL-PM, SolarLake 15000TL-PM, SolarLake17000TL-PM, SolarLake 20000TL-PM |
| Technical Specification | : | P65, Class I; SolarLake 12000TL-PM Input 400-1000Vd.c, max. 17Ax2; Output 230/400V 50Hz, max. 17,5A, 12000W(NOM) SolarLake 15000TL-PM Input 400-1000Vd.c, max. 21Ax2; Output 230/400V 50Hz, max. 22A, 15000W(NOM) SolarLake 17000TL-PM Input 440-1000Vd.c, max. 21Ax2; Output 230/400V 50Hz, max. 25A, 17000W(NOM) SolarLake 20000TL-PM Input 440-1000Vd.c, max. 24Ax2; Output 230/400V 50Hz, max. 29A, 20000W(NOM) |
| Brand name | : |  |
| Relevant Standard(s) | : | NRS 097-2-1: 2010 IEC 61727:2004 IEC 62116:2008 |
| Verification Number | : | EFSH201608-V001 |
| Report Number(s) | : | EFSH16070605-IE-01-L01 |

NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.

This is the result of tests carried out on those samples of the product referred to above which were submitted for testing, in accordance with the specification for the respective standards. The sample(s) of the tested product has been found to comply with the relevant standard listed on this verification at the time the tests were carried out.

The manufacturer shall file and keep the documentation according to the rules of the applicable standard(s) and shall consider changes of the standard(s) if relevant. Additional requirements may be applicable such as additional standard(s) or local laws.


Jerry Hu
Manager
2016-07-26