



**BUREAU
VERITAS**

**Bureau Veritas
Consumer Products Services
Germany GmbH**

Businesspark A96
86842 Türkheim
Germany
+ 49 (0) 4074041-0
cps-tuerkheim@de.bureauveritas.com

Certification body of BV CPS GmbH
Accredited according to EN 45011 -
ISO / IEC Guide 65

Certificate of conformity NS protection

Manufacturer / applicant: Samil Power Co., Ltd.,
No.6, Xuefengshan Road,
Suqian High-tech Industrial Development Zone,
Jiangsu Province,
P.R.China

Type of grid and plant protection:	Integrated NS protection
Assigned to generation unit type:	SolarLake 5500TL-PM, SolarLake 7000TL-PM, SolarLake 8500TL-PM, SolarLake 10000TL-PM

Firmware version: Master DSP SW: V1.00; Slave DSP SW: V1.00; HMI DSP SW: V1.00

Connection rule: VDE-AR-N 4105:2011-08 – Power generation systems connected to the low-voltage distribution network
Technical minimum requirements for the connection to and parallel operation with low-voltage distribution networks.

Applicable standards / directives: DIN VDE V 0124-100 (VDE V 0124-100): 2012-07 – Grid integration of power generation systems – low voltage
Test requirements for power generation units to be connected and operated parallel with the low-voltage distribution networks

The above mentioned grid and plant protection has been tested and certified according to the test guideline VDE 0124-100. The electrical properties required in the connection rule are satisfied.

- Setting values and disconnect times
- Properly functioning functional chain "NS protection – interface switch"
- Technical requirements of the switching device
- Passive / active detection of stand-alone power systems
- Single-fault tolerance

The certificate contains the following information:

- Technical specifications of the NS protection and corresponding power generation types
- Setting values of the protection functions
- Trip values of the protection functions

BV project number: 13TH0482

Certificate number: U13-0849

Date of issue: 2013-12-06

Valid until: 2016-12-05

Certification body

Dieter Zitzmann



QUALITY



ENVIRONMENT



SOCIAL
ACCOUNTABILITY



Deutsche
Akkreditierungsstelle
D-ZE-12024-01-01

(A partial representation of the certificate requires
the written permission of BV CPS GmbH)



F.4 Requirements for the test report for the NS protection

Extract from test report for NS protection Nr. 13TH0482
 "Determination of electrical properties"

NS protection as integrated NS protection

Manufacturer / applicant:	Samil Power Co., Ltd., No.6, Xuefengshan Road, Suqian High-tech Industrial Development Zone, Jiangsu Province, P.R.China
Type of grid and plant protection:	Integrated NS protection
Assigned to generation unit type:	SolarLake 5500TL-PM, SolarLake 7000TL-PM, SolarLake 8500TL-PM, SolarLake 10000TL-PM
Firmware version:	Master DSP SW: V1.00; Slave DSP SW: V1.00; HMI DSP SW: V1.00
Integrated interface switch:	Type of switching equipment 1: FUJITSU FTR-K3AB012W-WG Type of switching equipment 2: FUJITSU FTR-K3AB012W-WG
Measurement period:	2013-11-18 bis 2013-11-29

Protection function	Setting value	Trip value	Disconnection time ^a
Voltage drop protection U <	184 V	183,4 V	89,8 ms
Rise-in-voltage protection U>	253 V	253 V	459 s ^b
Rise-in-voltage protection U>>	264,1 V	264 V	61,4 ms
Frequency decrease protection f<	47,50 Hz	47,50 Hz	51,0 ms
Frequency increase protection f>	51,50 Hz	51,50 Hz	57,0 ms

^a proper time of interface switch 10 ms

^b longest disconnection of the rise-in-voltage protection as a moving 10-minute-average, tested according clause 5.4.5.3.3 measurement a) of VDE 0124-100

The disconnect time (sum of trip time of grid and plant protection and delay time of interface switch) must not exceed 200ms.

A check of the overall functional chain "NS protection – interface switch" resulted in a successful disconnection.

The above mentioned grid and plant protection with the assigned power generation units has met the requirements for islanding detection with the help of the active method (resonant circuit test).

The above mentioned NS protection meets the requirements for synchronization.