



Certificate No.: SGS/100559/3

CERTIFICATE OF COMPLIANCE

Modification Addendum

This certificate is issued as a modification addendum to Certificate No.: SGS/100559 to confirm that **SGS Systems & Services Certification Pty Ltd** (Electrical Product Certification Services (EPCS) Australia) as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has certified the article described herein to comply with the minimum safety standards for which the Application has been made by :-

SAMIL POWER CO., LTD.
No. 66 Taihangshan Road
Suyu Economic Development Zone
Suqian City, Jianguo Province
P. R. CHINA

DESCRIPTION OF ELECTRICAL EQUIPMENT

Class:	Grid Connected Inverter Energy System																
Product:	Solar Inverter																
Trade Name / Manufacturer:	Samil Power																
Catalogue / Model No(s):	SolarRiver 3300TL; SolarRiver 4400TL; SolarRiver 5200TL																
Ratings:	<table border="0"> <tr> <td>Input:</td> <td>100-550 V d.c.; Class I; IP65</td> </tr> <tr> <td></td> <td>17.5 A (SolarRiver 3300TL)</td> </tr> <tr> <td></td> <td>21 A (SolarRiver 4400TL)</td> </tr> <tr> <td></td> <td>26 A (SolarRiver 5200TL)</td> </tr> <tr> <td>Output:</td> <td>230 V a.c.; 50 Hz</td> </tr> <tr> <td></td> <td>16 A; 3000 W (SolarRiver 3300TL)</td> </tr> <tr> <td></td> <td>22 A; 4000 W (SolarRiver 4400TL)</td> </tr> <tr> <td></td> <td>24 A; 4600 W (SolarRiver 5200TL)</td> </tr> </table>	Input:	100-550 V d.c.; Class I; IP65		17.5 A (SolarRiver 3300TL)		21 A (SolarRiver 4400TL)		26 A (SolarRiver 5200TL)	Output:	230 V a.c.; 50 Hz		16 A; 3000 W (SolarRiver 3300TL)		22 A; 4000 W (SolarRiver 4400TL)		24 A; 4600 W (SolarRiver 5200TL)
Input:	100-550 V d.c.; Class I; IP65																
	17.5 A (SolarRiver 3300TL)																
	21 A (SolarRiver 4400TL)																
	26 A (SolarRiver 5200TL)																
Output:	230 V a.c.; 50 Hz																
	16 A; 3000 W (SolarRiver 3300TL)																
	22 A; 4000 W (SolarRiver 4400TL)																
	24 A; 4600 W (SolarRiver 5200TL)																
Standard No.:	Updated to: AS/NZS 3100:2009 and AS/NZS 4777.2:2005 and AS/NZS 4777.3:2005 and IEC 62109-2:2011 and IEC 62109-1:2010																

REQUIRED MARKING:	SGSE/100559
EXPIRY DATE:	22 September 2015
DATE OF CERTIFICATION:	21 September 2010
DATE OF MODIFICATION:	17 June 2013



[Signature]

 For and On Behalf of
SGS Systems & Services Certification Pty Ltd

