



Type Verification Test Report (UK-G59 Issue 3)

It includes the Generating Units supplier declaration of compliance with the requirements of Engineering Recommendation G59/3.			
Type Tested Reference Number		Photovoltaic Grid-tied Inverter	
Generating Unit Type		SolarRiver 4400TL/SolarRiver 5200TL	
System Supplier Name		Samil Power Co., Ltd.	
Address		No.6 Xuefengshan Road, Suqian High-tech Industrial Development Zone, Jiangsu Province, P. R. China	
Tel	+86-510-83593132	Fax	+86-510-83593136
E:mail	info@samilpower.com	Web site	www.samilpower.com
Maximum Rated Capacity	Connection Option		
	4.4	kW single phase (SolarRiver 4400TL)	
	5.0	kW single phase (SolarRiver 5200TL)	
	NA	kW three phases	
	NA	kW two phases in three phases system	
NA	kW two phases split phases system		
SSEG manufacturer/supplier declaration.			
I certify on behalf of the company named above as a supplier of a generating unit, that all products supplied by the company with the above Type Test reference number will be manufactured and tested to ensure that they perform as stated in this document, prior to shipment to site and that no site modifications are required to ensure that the product meets all the requirements of G59/3.			
Signed			On behalf of
			Samil Power Co., Ltd.



SolarRiver 4400TL				
Power Quality. Harmonics.				
SSEG rating per phase (rpp)		4	kW	
Harmonic	At 45-55% of rated output	100% of rated output		
	Measured Value (MV) in Amps	Measured Value (MV) in Amps	Limit in BS EN 61000-3-2 in Amps	Higher limit for odd harmonics 21 and above
2	0.001	0.003	1.080	
3	0.145	0.177	2.300	
4	0.004	0.006	0.430	
5	0.104	0.111	1.140	
6	0.003	0.006	0.300	
7	0.053	0.073	0.770	
8	0.002	0.004	0.230	
9	0.056	0.051	0.400	
10	0.002	0.005	0.184	
11	0.071	0.032	0.330	
12	0.016	0.004	0.153	
13	0.053	0.033	0.210	
14	0.001	0.017	0.131	
15	0.066	0.028	0.150	
16	0.006	0.018	0.115	
17	0.077	0.024	0.132	
18	0.030	0.003	0.102	
19	0.102	0.014	0.118	
20	0.033	0.024	0.092	
21	0.087	0.008	0.107	0.160
22	0.016	0.016	0.084	
23	0.074	0.009	0.098	0.147
24	0.005	0.006	0.077	
25	0.091	0.010	0.090	0.135
26	0.004	0.005	0.071	



ENGINEERING RECOMMENDATION G59/3

CERTIFICATE & SAFETY – R&D

TR 10006

Page 3 of 10

27	0.076	0.028	0.083	0.124
28	0.018	0.005	0.066	
29	0.081	0.010	0.078	0.117
30	0.004	0.012	0.061	
31	0.072	0.007	0.073	0.109
32	0.009	0.013	0.058	
33	0.055	0.012	0.068	0.102
34	0.006	0.012	0.054	
35	0.052	0.011	0.064	0.096
36	0.004	0.004	0.051	
37	0.049	0.017	0.061	0.091
38	0.005	0.012	0.048	
39	0.044	0.016	0.058	0.087
40	0.004	0.010	0.046	

Note the higher limits for odd harmonics 21 and above are only allowable under certain conditions, if these higher limits are utilised please state the exemption used as detailed in part 6.2.3.4 of BS EN 61000-3-2 in the box below.



SolarRiver 5200TL				
Power Quality. Harmonics.				
SSEG rating per phase (rpp)		4.6	kW	
Harmonic	At 45-55% of rated output	100% of rated output		
	Measured Value (MV) in Amps	Measured Value (MV) in Amps	Limit in BS EN 61000-3-2 in Amps	Higher limit for odd harmonics 21 and above
2	0.002	0.014	1.080	
3	0.169	0.140	2.300	
4	0.007	0.013	0.430	
5	0.105	0.083	1.140	
6	0.009	0.009	0.300	
7	0.068	0.034	0.770	
8	0.015	0.013	0.230	
9	0.041	0.105	0.400	
10	0.014	0.008	0.184	
11	0.029	0.099	0.330	
12	0.003	0.005	0.153	
13	0.016	0.099	0.210	
14	0.008	0.005	0.131	
15	0.028	0.145	0.150	
16	0.007	0.010	0.115	
17	0.023	0.128	0.132	
18	0.007	0.005	0.102	
19	0.027	0.131	0.118	
20	0.006	0.006	0.092	
21	0.023	0.132	0.107	0.160
22	0.006	0.010	0.084	
23	0.018	0.109	0.098	0.147
24	0.002	0.010	0.077	
25	0.046	0.132	0.090	0.135
26	0.011	0.011	0.071	



27	0.015	0.130	0.083	0.124
28	0.018	0.007	0.066	
29	0.031	0.105	0.078	0.117
30	0.010	0.012	0.061	
31	0.031	0.095	0.073	0.109
32	0.015	0.008	0.058	
33	0.027	0.076	0.068	0.102
34	0.013	0.008	0.054	
35	0.014	0.075	0.064	0.096
36	0.006	0.005	0.051	
37	0.022	0.069	0.061	0.091
38	0.002	0.004	0.048	
39	0.021	0.061	0.058	0.087
40	0.005	0.000	0.046	

Note the higher limits for odd harmonics 21 and above are only allowable under certain conditions, if these higher limits are utilised please state the exemption used as detailed in part 6.2.3.4 of BS EN 61000-3-2 in the box below.



SolarRiver 4400TL								
Power Quality. Voltage fluctuations and Flicker.								
	Starting			Stopping			Running	
	d_{max} [%]	d_c [%]	$d_{(t)}$ [%]	d_{max} [%]	d_c [%]	$d_{(t)}$ [%]	P_{st}	P_{it} 2 hours
Measured Values	0.37	1.0	0.44	0.37	1.0	0.44	0.164	0.085
Normalised to standard impedance and 3.68kW for multiple units	0.65	1.76	0.77	0.65	1.76	0.77	0.287	0.149
Limits set under BS EN 61000-3-2	4%	3.3%	3.3% 500ms	4%	3.3%	3.3% 500ms	1.0	0.65
Test start date	01\06\2010			Test end date	01\06\2010			
Test location	Laboratories No.52, HuiGu Innovation Park, Huishan District, Wuxi City, Jiangsu Province							

SolarRiver 5200TL								
Power Quality. Voltage fluctuations and Flicker.								
	Starting			Stopping			Running	
	d_{max} [%]	d_c [%]	$d_{(t)}$ [%]	d_{max} [%]	d_c [%]	$d_{(t)}$ [%]	P_{st}	P_{it} 2 hours
Measured Values	0.37	1.0	0.44	0.37	1.0	0.44	0.164	0.085
Normalised to standard impedance and 3.68kW for multiple units	0.65	1.76	0.77	0.65	1.76	0.77	0.287	0.149
Limits set under BS EN 61000-3-2	4%	3.3%	3.3% 500ms	4%	3.3%	3.3% 500ms	1.0	0.65
Test start date	01\06\2010			Test end date	01\06\2010			
Test location	Laboratories No.52, HuiGu Innovation Park, Huishan District, Wuxi City, Jiangsu Province							



SolarRiver 4400TL				
Power Quality. DC injection.				
Test power level	10%	55%	100%	
Recorded value	0.035	0.032	0.021	
as % of rated AC current	0.159	0.145	0.095	
Limit	0.25%	0.25%	0.25%	

SolarRiver 5200TL				
Power Quality. DC injection.				
Test power level	10%	55%	100%	
Recorded value	0.034	0.032	0.014	
as % of rated AC current	0.142	0.133	0.058	
Limit	0.25%	0.25%	0.25%	

SolarRiver 4400TL				
Power Quality. Power factor.				
	216.2V	230V	253V	Measured at three voltage levels and at full output. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test.
Measured value	0.9980	0.9976	0.9966	
Limit	>0.95	>0.95	>0.95	

SolarRiver 5200TL				
Power Quality. Power factor.				
	216.2V	230V	253V	Measured at three voltage levels and at full output. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test.
Measured value	0.9992	0.9989	0.9980	
Limit	>0.95	>0.95	>0.95	



Protection. Frequency tests						
Function	Setting		Trip test		"No trip tests"	
	Frequency	Time delay	Frequency	Time delay	Frequency/Time	Confirm no trip
U/F stage 1	47.5Hz	20s	47.5	20.085	47.7Hz/ 25s	No Trip
U/F stage 2	47Hz	0.5s	47.0	0.650	47.2Hz/ 19.98s	No Trip
					46.8Hz/ 0.48s	No Trip
O/F stage 1	51.5Hz	90s	51.50	90.117	51.3Hz/ 95s	No Trip
O/F stage 2	52Hz	0.5s	52.0	0.578	51.8Hz/ 89.98s	No Trip
					52.2Hz/0.48s	No Trip

Protection. Voltage tests						
Function	Setting		Trip test		"No trip tests"	
	Voltage	Time delay	Voltage	Time delay	Voltage /Time	Confirm no trip
U/V stage 1	200.1 V	2.5s	198.5	2.5	204.1V/ 3.5s	No trip
U/V stage 2	184 V	0.5s	182.2	0.502	188V/ 2.48s	No trip
					180V/ 0.48s	No trip
O/V stage 1	262.2 V	1.0s	262.5	1.0	258.2V/ 2.0s	No trip
O/V stage 2	273.7 V	0.5s	272.0	0.507	269.7V/ 0.98s	No trip
					277.7V/ 0.48s	No trip

Note for Voltage tests the Voltage required to trip is the setting $\pm 3.45V$. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting $\pm 4V$ and for the relevant times as shown in the table above to ensure that the protection will not trip in error.



Protection. Loss of Mains test.						
To be carried out at three output power levels with a tolerance of plus or minus 5% in Test Power levels.						
Test Power	10%	55%	100%	10%	55%	100%
Balancing load on islanded network	95% of SSEG output	95% of SSEG output	95% of SSEG output	105% of SSEG output	105% of SSEG output	105% of SSEG output
Trip time. Limit is 0.5 seconds	0.22 s	0.17 s	0.21 s	0.25 s	0.26 s	0.22 s

Protection. Frequency change, Stability test				
	Start Frequency	Change	End Frequency	Confirm no trip
Positive Vector Shift	49.5Hz	+9 degrees		No trip
Negative Vector Shift	50.5Hz	-9 degrees		No trip
Positive Frequency Drift	49.5Hz	+0.19Hz/sec	51.5Hz	No trip
Negative Frequency Drift	50.5Hz	-0.19Hz/sec	47.5Hz	No trip

Protection. Re-connection timer.					
Test should prove that the reconnection sequence starts after a minimum delay of 20 seconds for restoration of voltage and frequency to within the stage 1 settings of table 1.					
Time delay setting	Measured delay	Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of table 1.			
30s	32s	At 266.2V	At 196.1V	At 47.4Hz	At 51.6Hz
Confirmation that the SSEG does not re-connect.		No re-connect	No re-connect	No re-connect	No re-connect



Fault level contribution.					
SolarRiver 4400TL			SolarRiver 5200TL		
For a Inverter SSEG			For a Inverter SSEG		
Time After Fault	Volts	Amps	Time After Fault	Volts	Amps
20ms	29.55	0.215	20ms	31.50	0.221
100ms	29.50	0.215	100ms	30.90	0.211
250ms	29.48	0.211	250ms	30.50	0.208
500ms	29.45	0.201	500ms	30.50	0.198
Time to trip	0.0206	In seconds	Time to trip	0.035	In seconds

- End of Document -